



HILLTOWN TOWNSHIP

13 West Creamery Road
P.O. Box 260
Hilltown, PA 18927
(215) 453-6000

November 22, 1995

Mr. Patrick McManus
Remedial Project Manager
U.S. EPA
841 Chestnut Street
Philadelphia, PA 19107

Dear Mr. McManus,

With regard to the Dublin T.C.E. water line extension, please be advised that when public water lines are extended in Hilltown Township, the Township does require fire protection in those water lines. These requirements are addressed in the current Hilltown Township Subdivision and Land Development Ordinance of 1981, as amended, as follows:

Section 512 - Public Water Supply Systems and Centralized Water Supply and Distribution Systems:

- (b) The developer shall construct water mains in such a manner as to make adequate water service available to each lot, building, or dwelling unit within the subdivision or land development. A minimum pressure of thirty-five (35) pounds per square inch shall be provided at each house or other building to be connected to the water supply main. The water supply must comply with the regulations and the standards of the State Department of Environmental Resources.

Ordinance #87-3, adopted May 5, 1987 - Section 513A - Public and Community Water Supply and Distribution Systems:

- (d) The system shall also be designed with adequate capacity and appropriately spaced fire hydrants for fire fighting purposes as determined by the Township.

If you should have any further questions, please do not hesitate to contact me. Thank you.

Sincerely,


Bruce G. Horrocks
Township Manager

AR301717